

## 2019 Sustainable Energy Program Commercial Heat Pump/Air Conditioner Incentives

Central air conditioners below 65,000 Btuh cooling capacity. The system must meet both the EER and SEER minimums listed.

Cooling Efficiency			Incentive per system
Minimum EER	And	Minimum SEER	
12.0		13.0	\$200
13.0		13.0	\$200
14.0		13.0	\$200
12.0		15.0	\$300
13.0		15.0	\$300
14.0		15.0	\$300
13.0		16.0	\$400
14.0		16.0	\$400
14.0 +		18.0 +	\$500

Air source heat pumps below 65,000 Btuh cooling capacity. The system must meet both the EER and SEER minimums listed.

Cooling Efficiency			Incentive per system
Minimum EER	And	Minimum SEER	
12.0		14.0	\$200
13.0		14.0	\$200
14.0		14.0	\$200
12.0		15.0	\$300
13.0		15.0	\$300
14.0		15.0	\$300
13.0		16.0	\$400
14.0		16.0	\$400
14.0 +		18.0 +	\$500

\* First time installation of a geothermal heat pump.  
(including closed loop, open loop and "California loop")

Minimum EER	Cooling Efficiency	Incentive per system	
18.0 +		\$1,100	(if no domestic water heating desuperheater is used)
18.0 +		\$1,500	(if the system desuperheater is connected to the domestic water heater)

### Other commercial systems

\*\*Single package air conditioners and heat pumps (Greater than or equal to 65,000 Btuh)

\*\*VRF or VRV air conditioner and heat pump (greater than or equal to 65,000 Btuh)

Chillers

All incentives in this category will be determined by LES staff using a cost-benefit analysis.

\* Replacement commercial geothermal and "California Loop" heat pumps do not qualify for an incentive.

\*\*EER must exceed the ASHRAE 90.1-2013 minimum by at least 1.0 point in order to be considered for an incentive.

All incentives will be based on the AHRI full load cooling capacity and full load cooling efficiency